




## Type Examination Certificate

**CML 15ATEX4042**

**Issue 2**

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC
- 2 Equipment **Gamma LED Luminaire**
- 3 Manufacturer **Abtech Ltd**
- 4 Address 199 Newhall Road,  
Lower Don Valley,  
Sheffield,  
S9 2QJ,  
UK
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Certification Management Limited, Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design of equipment intended for use in potentially explosive atmospheres given in Annex II of Directive 94/9/EC.  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates the equipment is subject to conditions of certification affecting correct installation or safe use. These are specified in Section 14.
- 8 This Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 94/9/EC Article 8 apply to the manufacture of the equipment or component.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:  
EN 60079-0:2012:A11:2013                      EN 60079-15:2010                      EN 60079-31:2014
- 10 The equipment shall be marked with the following:



II 3 G D

Ex nA IIC T\* Gc  
Ex tc IIIC T\*\*°C Dc

Ta= Up to -50°C to +70°C

See description for Temperature class and ambient temperatures



**CML 15ATEX4042  
Issue 2**

## 11 Description

The Abtech Gamma LED Floodlight / Low bay luminaire is a range of Non sparking (Ex nA) luminaires, rated at 110V ac to 254 Vac. The Gamma LED Floodlight comprises of a single enclosure, manufactured from either stainless steel or mild steel protected from corrosion by a suitable coating. Optionally, an additional coating may be applied to the stainless steel versions. Silicone rubber gaskets are used to seal the enclosures.

The main enclosure, approximately 400 mm high by 400 mm wide and a depth of 110 mm. The enclosure may be manufactured larger than minimum/typical dimensions.

The enclosure is sealed using a toughened safety glass window. The enclosure houses a metal reflector, LED driver and an optical assembly comprising of Philip Luxeon M LED's and acrylic rods, optionally other LED's maybe used provided the given surface temperatures are not exceeded.

The normal method of mounting is via a single saddle bracket; alternatively any other method of mounting may be used providing the enclosure is not penetrated. The driver compartment, accessible through the rear cover, houses the electronic driver and the mains terminal block

Cable entry holes for conduit, suitably approved cable glands or blanking plugs can be fitted into any face of the enclosure provided clearance for the cable gland and cables is sufficient. These must be sealed to minimum IP64 or higher to match IP rating.

See table \* for details of wattage, T ratings and ambient temperature range.

Rating schedule – Voltage range: 110 ~ 254 Vac (Nominal), Up to -50°C to +55°C									
Product Ref.	LED Type	Current /Voltage	Power	Driver	Temp class and Surface Temp				Cable rating
					Tamb 55°C		Tamb 40°C		
LX2GA6L-30	LXR7-SW30	0.7A / 34.5V	97 W	EUC-16Q070DV	T3	T100°C	T4	T85°C	80°C
LX2GA6L-40	LXR7-SW40	0.7A / 34.5V	97 W	EUC-16Q070DV	T3	T100°C	T4	T85°C	80°C
LX2GA6L	LXR7-SW50	0.7A / 34.5V	97 W	EUC-16Q070DV	T3	T100°C	T4	T85°C	80°C
LX2GA6L-57	LXR7-SW57	0.7A / 34.5V	97 W	EUC-16Q070DV	T3	T100°C	T4	T85°C	80°C
LX2GA6L-65	LXR7-SW65	0.7A / 34.5V	97 W	EUC-16Q070DV	T3	T100°C	T4	T85°C	80°C

Note: Current stated above is maximum allowable and voltage is nominal and may be different depending on the driver fitted.



**CML 15ATEX4042  
Issue 2**

Rating schedule – Voltage range: 110 ~ 254 Vac (Nominal), Up to -50°C to +55°C									
Product Ref.	LED Type	Current /Voltage	Power	Driver	Temp class and Surface Temp				Cable rating
					Tamb 55°C		Tamb 40°C		
LX2GAM4 LB-40	PW40-H001	0.688A / 35.02V	96 W	EUC-096S070DV	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB-50	PW50-H001	0.688A / 35.02V	96 W	EUC-096S070DV	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB	PW57-H001	0.688A / 35.02V	96 W	EUC-096S070DV	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB-65	PW65-H001	0.688A / 35.02V	96 W	EUC-096S070DV	T3	T100°C	T4	T85°C	80°C

Note: Current stated above is maximum allowable and voltage is nominal and may be different depending on the driver fitted.

Rating schedule – Voltage range: 108 ~ 279 Vac (Maximum), Up to -40°C to +70°C									
Product Ref.	LED Type	Current /Voltage	Power	Driver	Temp class and Surface Temp				Cable rating
					Tamb 55/70°C		Tamb 40°C		
LX2GAM4L B-40	PW40-H001	0.688A / 35.02V	<96 W	T1M1UNV150 P-150L	T3	T100°C	T4	T85°C	83°C
LX2GAM4L B-50	PW50-H001	0.688A / 35.02V	<96 W	T1M1UNV150 P-150L	T3	T100°C	T4	T85°C	83°C
LX2GAM4L B	PW57-H001	0.688A / 35.02V	<96 W	T1M1UNV150 P-150L	T3	T100°C	T4	T85°C	83°C
LX2GAM4L B-65	PW65-H001	0.688A / 35.02V	<96 W	T1M1UNV150 P-150L	T3	T100°C	T4	T85°C	83°C

Note: Current and Voltage stated above is the maximum allowable.



**CML 15ATEX4042  
Issue 2**

### Variation 1

This variation introduces the following modifications:

- i. Permit the use of a new driver and LED arrangement, covered under the LX2GAM4LB series. The LX2GAM4LB Series alternatively has four pcb boards, each fitted with up to 84 LEDs and fed from a driver module, the alternative arrangements have the following ratings:

Rating schedule									
Product Ref.	LED Type	Current /Voltage	Power	Driver	Temp class and Surface Temp				Cable rating
					Tamb 55°C		Tamb 40°C		
LX2GAM4 LB-40	PW40-H001	0.688A / 35.02V	96 W	EUC-096S070D V	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB-50	PW50-H001	0.688A / 35.02V	96 W	EUC-096S070D V	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB	PW57-H001	0.688A / 35.02V	96 W	EUC-096S070D V	T3	T100°C	T4	T85°C	80°C
LX2GAM4 LB-65	PW65-H001	0.688A / 35.02V	96 W	EUC-096S070D V	T3	T100°C	T4	T85°C	80°C

### Variation 2

This variation introduces the following modifications:

- i. To include the previous variation 'Rating schedule' to the product description.
- ii. Permit the use of a alternative driver and higher ambient range, covered under the LX2GAM4LB series.

## 12 Certificate history and evaluation Reports

Issue	Date	Associated report	Notes
0	08/04/2015	R482A/00	Issue of prime certificate
1	21/12/2015	R925A/00	To introduce Variation 1
2	03/12/2018	R12152A/00	To introduce Variation 2

Note: Drawings that describe the equipment or component are listed in the Annex.

## 13 Conditions of manufacture

The following conditions are required of the manufacturing process for compliance with the certification.



**CML 15ATEX4042  
Issue 2**

- 13.1 Where the product incorporates certified parts or safety critical components the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- 13.2 Each unit manufactured shall be subjected to a electric strength test in accordance with EN 60079 15:2010 clause 23.2.1 at 1000v +2Un for 60 s. Alternately at 1.2 times this test voltage for at least 100 ms.
- 13.3 The manufacturer shall mark a maximum ambient range of -40°C to +70°C when fitting the T1M1UNV150P-150L driver, depending on Temperature class.

**14 Specific Conditions of Use (Special Conditions)**

None

## Certificate Annex

**Certificate Number** CML 15ATEX4042  
**Equipment** Gamma LED Luminaire  
**Manufacturer** Abtech Ltd



The following documents describe the equipment or component defined in this certificate:

### Issue 0

Drawing No	Sheets	Rev	Approved date	Title
ABT28409	1 of 1	A	08/04/2015	Gamma Label Drawing
ABT28321	1 of 1	A	08/04/2015	Gamma Floodlight GA Certification Drawing

### Issue 1

Drawing No	Sheets	Rev	Approved date	Title
ABT30009	1 to 3	A	21/12/2015	GAMMA FLOODLIGHT GA CERTIFICATION DRAWING
ABT30010	1 of 1	A	21/12/2015	GAMMA LABEL DRAWING

### Issue 2

Drawing No	Sheets	Rev	Approved date	Title
ABT30009	1 to 3	C	03/12/2018	GAMMA FLOODLIGHT GA CERTIFICATION DRAWING
ABT30010	1 of 1	C	03/12/2018	GAMMA LABEL DRAWING