



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

证书编号/No.: 2021122303114401

认证委托人名称: Abtech Ltd.

认证委托人地址: 199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

生产者名称: Abtech Ltd.

生产者地址: 199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

生产企业名称: Abtech Ltd. (L046553)

生产企业地址: 199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

认证依据标准: GB 3836.1-2010, GB 3836.3-2010, GB 12476.1-2013, GB 12476.5-2013

产品名称: 接线箱

系列/型号/规格: HVJB-7, HVJB-8, HVJB-125, NKJB-7, NKJB-8; 电气参数见附件; 防爆标志见附件

上述产品符合《强制性产品认证实施规则 防爆电气》(CNCA-C23-01: 2019)的要求, 特发此证。

发证日期: 2021年07月02日

有效期至: 2026年07月01日

此证书的有效性以定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 或产品客服电话 400-176-1888 查询。



Handwritten signature



方圆标志认证集团

地址: 北京市海淀区增光路33号(100048)

<http://www.cqm.com.cn>

A 0048829



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. 2021122303114401

NAME AND ADDRESS OF THE APPLICANT

Abtech Ltd.

199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

NAME AND ADDRESS OF THE MANUFACTURER

Abtech Ltd.

199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

NAME AND ADDRESS OF THE FACTORY

Abtech Ltd.

199+201 Newhall Road, Lower Don Valley, Sheffield, S9 2QJ, United Kingdom

CERTIFICATION STANDARDS

GB 3836.1-2010, GB 3836.3-2010, GB 12476.1-2013, GB 12476.5-2013

NAME, MODEL AND SPECIFICATION

Junction Boxes

HVJB-7, HVJB-8, HVJB-125, NKJB-7, NKJB-8; Refer to attachment for electrical parameters; Refer to attachment for Ex marking

THIS CERTIFICATE IS ISSUED AS VERIFICATION THAT THE PRODUCT(S) MENTIONED ABOVE HAS MET THE REQUIREMENTS OF IMPLEMENTATION RULES FOR CHINA COMPULSORY CERTIFICATION (REF NO. CNCA-C23-01: 2019)

INITIAL DATE: 2021-07-02

DATE OF EXPIRY: :2026-07-01

VALIDITY OF THIS CERTIFICATE IS SUBJECT TO POSITIVE RESULT OF THE REGULAR FOLLOW UP INSPECTION BY THE ISSUING CERTIFICATION BODY UNTIL THE EXPIRY DATE.

THE STATUS AND AUTHENTICITY OF THIS CERTIFICATE MAY BE VERIFIED BY VISITING THE OFFICIAL CNCA WEBSITE: WWW.CNCA.GOV.CN OR BY CONTACTING SERVICE TEL OF CQM: 400-176-1888



Handwritten signature



方圆标志认证集团

ADDRESS: No. 33 Zengguang Road, Haidian District Beijing P.R. China (100048)

<http://www.cqm.com.cn>

A 0048830



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 1 页 共 2 页

证书编号: 2021122303114401

主证纸号: A 0048829 A 0048830

型号: HVJB-7, HVJB-8, HVJB-125, NKJB-7, NKJB-8

防爆标志: Ex e II B/II C T4~T6 Gb, Ex tD A21 IP66 T70°C/T110°C

电气参数: 额定电压: 最高 11kV

最大耗散功率-高压和中压接线端子

型号	环境温度	最大耗散功率 (W)	气体环境温 度组别	粉尘环境 温度组别
HVJB-7	-20°C~+40°C	259	T4	T70°C
	-50°C~+55°C	129.5	T4	T70°C
	-50°C~+60°C	103.6	T4	T70°C
	-50°C~+55°C	259	T150°C	T110°C
HVJB-8	-20°C~+40°C	346	T4	T70°C
	-50°C~+55°C	173	T4	T70°C
HVJB-1 25	-50°C~+60°C	138.4	T4	T70°C
	-50°C~+55°C	246	T150°C	T110°C
NKJB-7	-20°C~+40°C	259	T4	T70°C
	-50°C~+55°C	259	T150°C	T110°C
NKJB-8	-20°C~+40°C	346	T4	T70°C
	-50°C~+55°C	346	T150°C	T110°C

注: 此附录与证书同时使用时有效。



Handwritten signature



方圆标志认证集团

<http://www.cqm.com.cn>

A 0048831



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 2 页 共 2 页

证书编号: 2021122303114401

主证纸号: A 0048829 A 0048830

配用现场连接件是的最大耗散功率

环境温度	最大耗散功率 (W)	
	现场连接件	高压端子
-20°C~+40°C	86.5	259.5
-50°C~+55°C	43.25	129.75
-50°C~+60°C	34.6	103.8

内部安装 BPG 接线盒时的最大耗散功率

型号	最大耗散功率和最大电流-电阻和导线					
	4 路		3 路		2 路	
	Power (W)	Current (A)	Power (W)	Current (A)	Power (W)	Current (A)
HVJB-7	不允许	不允许	248	938	165	624
HVJB-8	335	949	251	710	167	473

Ex 设备的特殊使用条件或 Ex 元件的限定使用条件: 无。

注: 此附录与证书同时使用时有效。



Handwritten signature



方圆标志认证集团

<http://www.cqm.com.cn>

A 0048832